



## ESTIMATED ANNUAL COOLING COST\*\*

		0.75 Ton	1 Ton	1.5 Ton	2 Ton	2.5 Ton	3 Ton
		9,000 BtuH	12,000 BtuH	18,000 BtuH	24,000 BtuH	30,000 BtuH	36,000 BtuH
SEER RATING	30	\$54	\$72	\$108	\$144	\$180	\$216
	29	\$56	\$74	\$112	\$149	\$186	\$223
	28	\$58	\$77	\$116	\$154	\$193	\$231
	27	\$60	\$80	\$120	\$160	\$200	\$240
	26	\$62	\$83	\$125	\$166	\$208	\$249
	25	\$65	\$86	\$130	\$173	\$216	\$259
	24	\$68	\$90	\$135	\$180	\$225	\$270
	23	\$70	\$94	\$141	\$188	\$235	\$282
	22	\$74	\$98	\$147	\$196	\$245	\$295
	21	\$77	\$103	\$154	\$206	\$257	\$309
	20	\$81	\$108	\$162	\$216	\$270	\$324
	19	\$85	\$114	\$171	\$227	\$284	\$341
	18	\$90	\$120	\$180	\$240	\$300	\$360
	17	\$95	\$127	\$191	\$254	\$318	\$381
	16	\$101	\$135	\$203	\$270	\$338	\$405
	15	\$108	\$144	\$216	\$288	\$360	\$432
	14	\$116	\$154	\$231	\$309	\$386	\$463
13	\$125	\$166	\$249	\$332	\$415	\$496	
12	\$135	\$180	\$270	\$360	\$450	\$540	
11	\$147	\$196	\$295	\$393	\$491	\$589	
10	\$162	\$216	\$324	\$432	\$540	\$648	
9	\$180	\$240	\$360	\$480	\$600	\$720	
8	\$203	\$270	\$405	\$540	\$675	\$810	

\*Based on 9 cent/KWH and 2000 Annual Cooling Hours

\*\*For Reference Only (Estimated Costs)

Note: 1 Ton ≈ 12,000 BTUs

Example:

Annual cooling cost to run a 2-ton (24,000 btuH ) air conditioner with a 10 SEER will be \$432.

If replaced with a high efficiency 28 SEER unit, the operating cost drops to \$154.

Savings of \$278 per year.